

ASBESTOS IDENTIFICATION REPORT

Date: 17 December 2015

ESP Job Number: J32598A

Customer: Axima

Address: 135 Boundary Road, Laverton North VIC

Attention: Karen Agius

Sampled From: Container TCNU6083590, Arrow Transport, 96-118 Toll Drive, Laverton North VIC

Sampled By: ESP – Environmental & Safety Professionals

Date Sampled: 16 December 2015

Test Method: Qualitative identification of asbestos types in bulk samples by polarised light microscopy, including dispersion staining, using ESP in-house Method No. 2 and methodology in accordance with AS4964.

ESP Lab No.	Sample location (if provided) and sample description	Result
E46737	1: 3 pack, batts – Insulation (80 x 70 x 10 mm)	No asbestos detected ²
E46738	2: 2 pack, batts – Insulation (80 x 40 x 10 mm)	No asbestos detected ²

The results contained in this report relate only to the sample(s) submitted for testing.

² Synthetic mineral fibre(s) detected.



WORLD RECOGNISED
ACCREDITATION

NATA Accredited Laboratory
Number: 3110

Accredited for compliance with ISO/IEC 17025

Rosie Fedele

Approved Identifier / Approved Signatory